

The background of the slide is a photograph of the TU Delft campus. A prominent feature is a tall, modern glass skyscraper with a red vertical stripe on its side. The foreground shows a wide, paved pedestrian walkway with several people walking. To the right, there are green lawns and trees. The sky is clear and blue.

LIFE CYCLE PERFORMANCE OF REFRIGERATION SYSTEMS IN THE DUTCH SUPERMARKET SECTOR

Carlos Infante Ferreira, Menno van der Hoff, Martien Janssen and Maus Dieleman




Fourth IIR Conference on
Thermophysical Properties and Transfer Processes of Refrigerants
June 17-19, 2013 Delft, The Netherlands



Content

Supermarket sector

1. INTRODUCTION
2. PLANT CHARACTERIZATION
3. ALTERNATIVE SYSTEMS CONSIDERED
 1. Supermarket systems
 2. Comparison with previous studies
4. CONCLUSIONS



Example of the lay-out of a R404A system for supermarket applications.

Supermarket Sector in NL

Sector information


Average operating hours per year [h]	Installed cooling capacity [kW]	Installed freezing capacity [kW]	Percentage R404A/R507 plants [%]	Percentage R22 plants [%]	Percentage R410A plants [%]	Percentage R134a plants [%]	Percentage R422D plants [%]	kg refrigerant/kW cooling
6132	100	20	84	9	4	2	1	2.7

Pennartz and van den Bovenkamp (2011)




Supermarket Sector in NL

Sector information



Leakage rate of refrigerants in sector [%]



Refrigeration 7 PJ
Total sector 11 PJ

Pennartz and van den Bovenkamp (2011)



Supermarket Sector in NL

Current size of sector

	Area [m ²]	Number of shops
Hypermarkets	>2500	65
Supermarkets	1350	1379
Discounters	<1000	2879.0
Total sector	3.8x10⁶	4323
MT range (-10°C)	74 W/m²	100 kW
LT range (-32°C)	15 W/m²	20 kW

Zadelhoff (2012)



Supermarket Sector in NL

Used refrigerants and leakage rates
(based on 34 supermarket plants)

	R404A/R507	R22	R422D	R134a	R410A
Percentage of total refrigerant weight [%]	94.8	4.4	0.5	0.2	0.1
Percentage of total shops [%]	83.5	9.0	0.7	1.7	4.1
Refrigerant leakage [%]	10.4	14.8	9.8	0.4	0.8
GWP [kg CO ₂] 100 yr	3700/3800	1790	2700	1370	2100

Jans (2010)



Supermarket application

Cooling capacity = 100 kW (MT) / 20 kW (LT)

Evaporation temperature MT = -10°C (indirect = -17°C)


Evaporation temperature LT = -32°C (indirect = -39°C)

Condensation temperature = 40°C (no heat recovery: variable)

Isentropic efficiency compressor = 0.613 (ammonia = 0.700)

Running time: 6132 hours/year

Minimum temperature difference in hex = 5 K



Supermarket application

Alternative systems considered

	System	Refrigerant inventory
1	Reference: Booster with direct evaporation of R404A	324 kg R404A
2	Booster with direct evaporation of R404A and internal heat exchangers	324 kg R404A
3	Booster with direct evaporation of HFO1234yf	324 kg HFO1234yf
4	Booster with direct evaporation of R744	324 kg CO ₂
5	Direct evaporation of R404A (MT) with R744 cascade (LT)	162 kg R404A + 162 kg CO ₂
6	Direct evaporation of HFO1234yf (MT) with R744 cascade (LT)	162 kg HFO1234yf + 162 kg CO ₂
7	Booster with R717 and secondary fluid for distribution (potassium formate)	24 kg R717
8	Booster with R290 and secondary fluid for distribution (potassium formate)	24 kg R290
9	R717 with R744 cascade, MT distribution with R744	24 kg R717 + 324 kg CO ₂
10	R290 with R744 cascade, MT distribution with R744	24 kg R290 + 324 kg CO ₂
11	Direct evaporation HFO1234yf (MT) and R404A (LT)	162 kg HFO1234yf + 162 kg R404A
12	Booster with R717 and secondary fluid for distribution (CO ₂)	24 kg R717 + 324 kg CO ₂



Plant characterization – Energetic performance

$$COP = \frac{\dot{Q}_{LT} + \dot{Q}_{MT}}{\dot{W}_{LT} + \dot{W}_{MT}}$$

$$P_{cond_fan} = 0.027 * (\dot{Q}_{LT} + \dot{Q}_{MT} + \dot{W}_{LT} + \dot{W}_{MT})$$


$$P_{evap_fan} = 0.04 * (\dot{Q}_{LT} + \dot{Q}_{MT})$$

$$P_{defrost} = 0.03 * (\dot{Q}_{LT} + \dot{Q}_{MT})$$

$$P_{anti-sweat} = 0.02 * (\dot{Q}_{LT} + \dot{Q}_{MT})$$

$$COPS = \frac{\dot{Q}_{LT} + \dot{Q}_{MT}}{\dot{W}_{LT} + \dot{W}_{MT} + P_{cond_fan} + P_{evap_fan} + P_{defrost} + P_{anti-sweat}}$$

$$PEU = \frac{\dot{Q}_{LT} + \dot{Q}_{MT}}{COPS} * 8760 * (\text{Refrigeration_load_ratio}) * \frac{1}{\eta_{elec}}$$




Plant characterization – Global warming / cost estimation

$$TEWI = GWP L_{annual} m_{charge} n + GWP m_{charge} (1 - \alpha_{recovery}) + n E_{annual} \beta$$

$$Cost = a * \dot{Q}^b$$

	Compressors				Condensers	
	R404A	HFO1234yf	CO2	R717	R404A	R717
a	824	1231	3827	1225	83.217	378.27
b	-0.4017	-0.4674	-0.7195	-0.4148	-0.0032	-0.2171

$$Cost = Cost(\text{compressor} + \text{condenser}) * 3.5$$



Supermarket application

Seasonal averaged

Altern.	\dot{W}_{LT} [kW]	\dot{W}_{MT} [kW]	Q_{cond} [kW]	P_{cond_fan} [kW]	P_{aux} [kW]	COP [-]	COPS [-]	PEU [TJ]	TEWI [ktonCO2 eq.]	TEWI [% direct emissions]	System costs [kEuro]	TCO [kEuro/year]
1	3.3	38.0	161.3	4.3	15.1	3.2	2.2	2.95	4.65	44.9	144.80	68.56
2	3.3	36.0	159.3	4.3	15.1	3.3	2.3	2.86	4.55	45.6	143.40	66.78
3	3.3	33.8	157.0	4.3	15.0	3.5	2.4	2.72	2.59	0.1	161.90	66.50
4	3.7	49.0	172.7	4.7	15.5	2.5	1.9	3.59	3.13	0.0	214.58	87.80
5	4.8	36.4	161.1	4.3	15.1	3.1	2.2	2.96	3.62	29.0	172.20	71.95
6	4.8	34.2	158.9	4.3	15.1	3.3	2.3	2.82	2.48	0.0	141.50	65.93
7	3.0	37.1	160.1	4.3	17.9	3.1	2.1	3.01	2.67	0.0	207.90	76.93
8	3.4	42.4	165.8	4.5	18.0	2.8	1.9	3.35	2.94	0.0	145.10	75.54
9	4.7	35.4	159.9	4.3	15.4	3.1	2.2	2.88	2.54	0.0	225.70	76.76
10	4.8	41.9	166.7	4.5	15.5	2.7	2.0	3.29	2.86	0.0	174.10	77.86
11	3.3	33.8	157.1	4.2	15.0	3.5	2.4	2.72	3.43	30.5	155.50	65.82
12	3.0	34.9	157.9	4.3	15.4	3.3	2.3	2.79	2.44	0.0	207.00	72.89

TCO (Total Cost of Ownership):

Depreciation period: 15 years

Interest: 8%

Energy costs: 150 €/MWh

Supermarket application

Ranking of systems

No condenser heat recovery					Condenser heat recovery				
Altern.	CSR	TCO	Safety	Total	Altern.	CSR	TCO	Safety	Total
	[ktonCO2 eq.]	[k€/year.]	[Class.]	score		[ktonCO2 eq.]	[k€/year.]	[Class.]	score
6	11.8	11.9	6.2	8.9	6	11.6	12.0	6.2	8.9
3	11.3	11.7	4.7	8.4	3	12.0	11.8	4.7	8.7
12	12.0	8.5	5.7	7.8	12	12.0	9.9	5.7	8.2
11	7.1	12.0	7.7	7.6	8	9.4	8.2	12.0	7.8
8	9.5	7.1	12.0	7.5	11	7.4	12.0	7.7	7.7
9	11.5	6.5	5.7	6.9	9	11.7	8.5	5.7	7.7
10	9.9	6.0	6.0	6.3	7	11.0	8.1	1.0	6.5
5	6.1	8.9	7.7	6.3	5	6.2	9.3	7.7	6.4
7	10.9	6.4	1.0	5.9	10	9.3	6.9	6.0	6.4
2	1.5	11.5	7.7	5.6	2	2.0	11.2	7.7	5.7
1	1.0	10.6	7.7	5.1	1	1.0	9.5	7.7	4.8
4	8.5	1.0	7.7	4.5	4	6.8	1.0	7.7	3.9

CSR (Corporate Social Responsibility):
 based on TEWI: lowest 12; highest 1
 Safety (safety class & amount of refrigerant)
 Total: $(CSR+TCO+0.5*Safety)/3.0$



Supermarket application

Ranking of systems

With heat recovery

Condenser heat recovery					
Altern.	CSR [ktonCO2 eq.]	TCO [k€/year.]	Safety [Class.]	Total score	
6	11.6	12.0	6.2	8.9	6 Direct evaporation of HFO1234yf (MT) with R744 cascade (LT)
3	12.0	11.8	4.7	8.7	3 Booster with direct evaporation of HFO1234yf
12	12.0	9.9	5.7	8.2	12 Booster with R717 and secondary fluid for distribution (CO2)
8	9.4	8.2	12.0	7.8	8 Booster with R290 and secondary fluid for distribution (potassium formate)
11	7.4	12.0	7.7	7.7	11 Direct evaporation HFO1234yf (MT) and R404A (LT)
9	11.7	8.5	5.7	7.7	9 R717 with R744 cascade, MT distribution with R744
7	11.0	8.1	1.0	6.5	7 Booster with R717 and secondary fluid for distribution (potassium formate)
5	6.2	9.3	7.7	6.4	5 Direct evaporation of R404A (MT) with R744 cascade (LT)
10	9.3	6.9	6.0	6.4	10 R290 with R744 cascade, MT distribution with R744
2	2.0	11.2	7.7	5.7	2 Booster with direct evaporation of R404A and internal heat exchangers
1	1.0	9.5	7.7	4.8	1 Reference: Booster with direct evaporation of R404A
4	6.8	1.0	7.7	3.9	4 Booster with direct evaporation of R744

CSR (Corporate Social Responsibility):
 based on TEWI: lowest 12; highest 1
 Safety (safety class & amount of refrigerant)
 Total: $(CSR+TCO+0.5*Safety)/2.5$

Comparison with previous studies

Major difference for CO₂ system


Altern.	PEUrelat	PEUrelat	Ratio
	[%]	[%]	
	This study	Rhiemeier	
1	100	100	1.0
2	97		
3	92		
4	121	100	1.2
5	100	100	1.0
6	96	93	1.0
7	102	115	0.9
8	113		
9	98	87	1.1
10	111	100	1.1
11	92	93	1.0
12	94		

Rhiemeier & Harnisch (2009)




Comparison with previous studies

Major difference for CO₂ system: CO₂ system



Comparison with previous studies

Major difference for CO₂ system: R404A system



Conclusions

Energy & Emissions (Reference is R404A)

Energetic performance:

Direct evaporation of HFO1234yf 8% savings

Direct evaporation of HFO1234yf (MT) +
direct evaporation of R404A (LT) 8% savings

Ammonia with CO2 distribution 5% savings

Emission reduction:

Ammonia with CO2 distribution 48% reduction

Direct evaporation of HFO1234yf (MT) +
CO2 cascade (LT) 47% reduction

Ammonia with CO2 distribution (MT) +
CO2 cascade (LT) 45% reduction

