

ORNL – LCCP: An extensible Framework for Life Cycle Climate Performance based Design of Energy Systems

Vikrant Aute (vikrant@umd.edu)



Contents

- 🌱 Background
- 🌱 Project Objectives
- 🌱 ORNL LCCP Framework
- 🌱 Demo

Emissions Due to HVAC&R

- Emissions occur throughout lifetime
 - Leakages, service & disposal
 - Operation
 - Manufacturing & transport
- Mitigation
 - Low/No GWP alternatives
 - Efficient recovery/reuse
 - Efficient systems
 - **Systems approach towards design**

Life Cycle Climate Performance

- Total CO₂ equivalent global warming impact over total lifetime of the system
- Comprised of
 - Direct emissions: refrigerant released
 - Indirect emissions
 - Energy consumption over lifetime and recycling
 - Power input during operation, transport, processing
 - Manufacturing of systems/components, recycling
- Units: kg CO₂ /kg OR CO₂ e

LCCP History

ORNL

- Life cycle analysis for alternative refrigerants
- Total Equivalent Warming Impact (TEWI)

Papasavva (1997)

- Expanded TEWI to Life Cycle Warming Impact (LCWI)

Andersen (1999)

- Montreal Protocol, Technology & Economic Assessment Panel
- Coined: Life Cycle Climate Performance (LCCP)

LCCP Software Efforts

- 🌱 GREEN-MAC LCCP (2004)
 - Automotive
 - Peer reviewed, contribution from 50 experts,
 - <http://www.epa.gov/cppd/mac/>
- 🌱 AHRTI (2011)
 - October 2011, AHRTI Report No. 09003-01
 - Residential heat pumps
- 🌱 ORNL – LCCP (2012)
 - Project at CEEE/UMD funded by DOE/ORNL

AHRI LCCP

- 🌱 ***Life Cycle Climate Performance Model for Residential Heat Pump Systems***
- 🌱 Excel-based simulation tool for calculating the direct and indirect emissions for residential heat pump systems
- 🌱 <http://www.ahrinet.org/technical+results.aspx>

Future Energy Systems








- ❖ Engineered for performance, cost,...., **LCCP**,....
- ❖ LCCP needs to be one of the design metric
- ❖ Should be one of the objectives or constraints during design optimization

Challenges

- 🌱 Standardized LC_{CP} calculation
- 🌱 Bring diverse set of analysis tools onto a single platform – without exposing any IP
 - Can serve as a platform or component of a bigger platform
- 🌱 System (refrigeration vs. A/C) independent
- 🌱 Transparent calculations, peer-reviewed
- 🌱 Input uncertainty
- 🌱 Standardized outputs

ORNL LCCP Objectives

Design Tool

-  Build on existing methodologies
-  Extensible framework for LCCP design
 -  Can be coupled with existing system/load calculations tools
-  Wide range of applications
 -  Supermarket refrigeration, heat pumps,...
-  Desktop and Web/Cloud based interfaces
-  Open Source

LCCP

Direct Emissions

- Regular emissions
- Irregular emissions
- Service emissions
- End-of-life emission
- Leakage during production & transport

Indirect Emissions

- Energy consumption of the system
- Energy to make system/components
- Energy to produce refrigerant
- Energy to transport
- Energy for end-of-life, recycling/recovery of system and refrigerant

* Also included are place-holders for user-defined emissions

Direct Emissions

$$Em_{\text{direct}} = Em_{\text{ref,leak}} + Em_{\text{acc}} + Em_{\text{serv}} + Em_{\text{ref,EOL}} + Em_{\text{ref,prod}} + Em_{\text{reaction}}$$

$$Em_{\text{ref,leak}} = \text{Charge} * \text{System lifetime} * \text{Annual leak rate} * \text{GWP}$$

$$Em_{\text{acc}} = \text{Charge} * \text{System lifetime} * \text{Annual accident leak rate} * \text{GWP}$$

$$Em_{\text{serv}} = \text{Total number of services} * \text{Charge} * \text{Servicing leak rate} * \text{GWP}$$

$$Em_{\text{ref,EOL}} = \text{Percent of refrigerant lost at end of life} * \text{Charge} * \text{GWP}$$

$$Em_{\text{ref,prod}} = \text{Ref production \& transportation leak rate} * \text{Charge} * \text{GWP}$$

Indirect Emissions

$$Em_{\text{indirect}} = Em_{\text{sys,man}} + Em_{\text{ref,man}} + Em_{\text{sys,EOL}} + Em_{\text{ref,disp}} + Em_{\text{elec}} + Em_{\text{sys,trans}}$$


$$Em_{\text{sys,man}} = \text{Mass of each material} * \text{CO}_2 \text{ equivalent}$$

$$Em_{\text{ref,man}} = \text{Charge} * (1 + \text{System lifetime} * \text{Annual leak rate} - \text{Percent of reused refrigerant}) * \text{CO}_2 \text{ equivalent emissions for virgin refrigerant}$$

$$Em_{\text{sys,EOL}} = \text{Energy of recycling of metals} * \text{Mass of metals} \\ * \text{CO}_2 \text{ equivalent of metals} + \text{Energy of recycling of plastics} \\ * \text{Mass of plastics} * \text{CO}_2 \text{ equivalent of plastics}$$

$$Em_{\text{sys,elec}} = \text{System lifetime} * \sum_{n=0}^{8760} \text{Hourly energy consumed} * \text{Emission rate for location}$$

ORNL LCCP Framework



Components will be developed as “Open Source”.
Other components can be open-source or proprietary

LCCP Inputs

System

- Lifetime, leak rates, service intervals, power consumption, charge,..

Refrigerant

- GWP, manufacturing, transport, leakage, recycling energy

Components

- Manufacturing, transport, recycling

Application

- Weather, power-plant emissions, renewable factor

* Also included are place-holders for user-defined inputs

Role of System Simulation Tool

- 🌱 Indirect emissions: 40%-80% of total
- 🌱 LCCP approach involves hourly energy consumption calculations, 8760 evaluations
- 🌱 Robust system simulation tool
 - For novel systems
 - Fast & flexible
 - Allow system design/optimization with LCCP as one of the criterion

ORNL LCCP Web App

- 🌱 Supermarket refrigeration
 - Design capability
- 🌱 Residential air source heat pump
 - Evaluation and design capability
 - ANSI/AHRI Standard 210/240

ORNL LCCP tools can be found at:

<http://lccp.umd.edu/>

Life Cycle Climate Performance - V0.28



[LCCP Design Tool for Supermarket Refrigeration Systems](#)

[LCCP Evaluation Tool for Residential Heat Pump Systems](#)

[LCCP Design Tool for Residential Heat Pump Systems](#)

ORNL LCCP Web App

Life Cycle Climate Performance - Supermarket Refrigeration



LCCP INPUT PARAMETERS

RUN


Select System Type Select Load Profile Select City

[Load-profile curve](#)

SYSTEM INPUTS

[Load sample values](#)

Refrigerant [-]	<input type="text" value="R404A"/>	Subcooling at Expansion Device [F]	<input type="text" value="50.4"/>
System Charge [lb]	<input type="text" value="4409.25"/>	Superheat at Evaporator Outlet [F]	<input type="text" value="65.0"/>
Annual Leak Rate [%]	<input type="text" value="5"/>	Suction Line Temperature Increase [F]	<input type="text" value="50.0"/>
Refrigerant Loss-EOL [%]	<input type="text" value="15"/>	Cut-off Temperature [F]	<input type="text" value="55.0"/>
System Lifetime [yrs]	<input type="text" value="15"/>	Nominal Load [Btu/hr]	<input type="text" value="300023.5"/>
Service Leakage Rate [%]	<input type="text" value="0.05"/>	Service Interval [year]	<input type="text" value="5"/>
Liquid Line Temperature Decrease [F]	<input type="text" value="50.0"/>		



COMPONENT INPUTS

[Load HTC values](#)

COMPRESSOR

Isentropic Efficiency [%]	<input type="text" value="65"/>	RPM [-]	<input type="text" value="3600"/>
Volumetric Efficiency [%]	<input type="text" value="80"/>	Displacement [in ³]	<input type="text" value="8.54"/>
Number of compressors [-]	<input type="text" value="10"/>		

CONDENSER

Air Side HTC [Btu/hrft ² F]	<input type="text" value="17.61"/>	Diameter [in]	<input type="text" value="1.13"/>
Ref Liquid HTC [Btu/hrft ² F]	<input type="text" value="176.11"/>	Tube Length [in]	<input type="text" value="1200.00"/>
Number of circuits [-]	<input type="text" value="1"/>	Number of tubes [tubes/circuit]	<input type="text" value="12"/>
Ref Two Phase HTC [Btu/hrft ² F]	<input type="text" value="874.22"/>	Fin Ratio [-]	<input type="text" value="15"/>
Ref Vapor HTC [Btu/hrft ² F]	<input type="text" value="105.67"/>	Air Flow Rate(per circuit) [CFM]	<input type="text" value="42377.60"/>

EVAPORATOR

Air Side HTC [Btu/hrft ² F]	<input type="text" value="17.61"/>	Diameter [in]	<input type="text" value="0.38"/>
Ref Liquid HTC [Btu/hrft ² F]	<input type="text" value="176.11"/>	Tube Length [in]	<input type="text" value="2400.00"/>
Number of circuits [-]	<input type="text" value="1"/>	Number of tubes [tubes/circuit]	<input type="text" value="10"/>
Ref Two Phase HTC [Btu/hrft ² F]	<input type="text" value="1322.78"/>	Fin Ratio [-]	<input type="text" value="15"/>
Ref Vapor HTC [Btu/hrft ² F]	<input type="text" value="105.67"/>	Air Flow Rate(per circuit) [CFM]	<input type="text" value="25426.56"/>

RUN



ORNL LCCP Web App



ASHP system evaluation tool

Life Cycle Climate Performance - Residential Heat Pump

OAK RIDGE NATIONAL LABORATORY ETSO
Supported by US DOE for the National Energy Research Scientific Computing Center



General system inputs

SYSTEM SETTINGS

System Type: Performance: City:
Calculation Type: Backup Heat: Refrigerant:

SYSTEM PROPERTIES

System Lifetime(yr): Ref Loss EOL(%): System Charge(lbm):
Annual Leak Rate(%): Service Interval(yr): Service Leak Rate(%):

Unit Temperature Switch Cycle Degradation Coefficients Design Heating requirement

T_off(F): Cd_c(-): DHR Selection:
T_on(F): Cd_h(-):

Backup Heat-Fuel Combustion Data

Heat Value(MBtu/lb fuel): CO2 Emission(lbCO2/lb-fuel): Combustion Efficiency(%):

Required for backup heat with gas/oil

HP COMPONENT MANUFACTURING - MASS & CO2 EQUIVALENT EMISSIONS (SIMPLE)

Total System Mass(lbm): Aluminum Mass(%): Copper Mass(%):
Plastics Mass(%): Steel Mass(%): Brass Mass(%):

- Test data inputs according to AHRI std 210/240
- Required for LCCP evaluation

AHRI Std 210/240 PERFORMANCE DATA

Cooling, A Test, Indoor (80F/67F), Outdoor (95F/75F)	Capacity(Btu/hr)	<input type="text" value="40704"/>	Total Power(W)	<input type="text" value="3444"/>
Cooling, A Test, Indoor (80F/67F), Outdoor (82F/65F)	Capacity(Btu/hr)	<input type="text" value="45100"/>	Total Power(W)	<input type="text" value="2931"/>
Heating, H1 Test, Indoor (70F/-), Outdoor (47F/43F)	Capacity(Btu/hr)	<input type="text" value="38600"/>	Total Power(W)	<input type="text" value="3353"/>
Heating, H2 Test, Indoor (70F/60F), Outdoor (35F/33F)	Capacity(Btu/hr)	<input type="text" value="30912"/>	Total Power(W)	<input type="text" value="3233"/>
Heating, H3 Test, Indoor (70F/60F), Outdoor (17F/15F)	Capacity(Btu/hr)	<input type="text" value="22199"/>	Total Power(W)	<input type="text" value="3064"/>

CALCULATE



ORNL LCCP Web App

ASHP system design tool

Similar to evaluation tool

- System sizing details
- Required for design based on LCCP

Life Cycle Climate Performance - Residential Heat Pump

OAK RIDGE NATIONAL LABORATORY **ETSD**
University of Tennessee, Knoxville, Tennessee

CEEE

SYSTEM SETTINGS

Performance: City: Refrigerant:

Calculation Type: Backup Heat:

SYSTEM PROPERTIES

System Lifetime(yr): Ref Loss EOL(%): System Charge(lbm):

Annual Leak Rate(%): Service Interval(yr): Service Leak Rate(%):

Unit Temperature Switch
T_off(F): T_on(F):

Cycle Degradation Coefficients
Cd_c(-): Cd_h(-):

Design Heating requirement
DHR Selection:

Backup Heat-Fuel Combustion Data

Heat Value(MBtu/lb fuel): CO2 Emission(lbCO2/lb-fuel): Combustion Efficiency(%):

HP COMPONENT MANUFACTURING - MASS & CO2 EQUIVALENT EMISSIONS (SIMPLE)

Total System Mass(lbm): Aluminum Mass(%): Copper Mass(%):

Plastics Mass(%): Steel Mass(%): Brass Mass(%):

AHRI Std 210/240 PERFORMANCE DATA

SYSTEM INPUTS

Subcooling at Expansion Device [F]: Superheat at Evaporator Outlet [F]:

Suction Line Temperature Increase [F]: Liquid Line Temperature Decrease [F]:

COMPONENT INPUTS

COMPRESSOR

Isentropic Efficiency [%]: RPM [-]: Volumetric Efficiency [%]:

Displacement [in³]: Number of compressors [-]:

CONDENSER

Air Side HTC [Btu/hrft²F]: Diameter [in]: Ref Liquid HTC [Btu/hrft²F]:

Tube Length [in]: Number of circuits [-]: Number of tubes [tubes/circuit]:

Ref Two Phase HTC [Btu/hrft²F]: Fin Ratio [-]: Ref Vapor HTC [Btu/hrft²F]:

Air Flow Rate(per circuit) [CFM]:

EVAPORATOR

Air Side HTC [Btu/hrft²F]: Diameter [in]: Ref Liquid HTC [Btu/hrft²F]:

Tube Length [in]: Number of circuits [-]: Number of tubes [tubes/circuit]:

Ref Two Phase HTC [Btu/hrft²F]: Fin Ratio [-]: Ref Vapor HTC [Btu/hrft²F]:

Air Flow Rate(per circuit) [CFM]:



ORNL LCCP Desktop App

- Supermarket refrigeration
- Residential air source heat pump
- Display cases using secondary refrigerants
- Water chiller

Application Information

System Inputs

Inputs Default Values

Select a Location

System Lifetime [yr]

Number of Cycles [Recommended Charge Value](#)

System Property	Cycle 1
System Type [-]	CentralizedDX
Refrigerant [-]	CentralizedDX
System Charge [lb]	SecondaryLoop
Nominal Load [Btu/hr]	ASHP
Annual Leakage Rate [%]	Display Cases Using Secondary Refrigerants
	Water Chiller

ORNL LCCP Desktop App

- Residential air-source heat pump
 - ANSI/AHRI Standard 210/240
 - Can be coupled with EnergyPlus for load calculation

ASHP System Information

System Type: Performance:

Calculation Type: Backup Heat:

Unit Temperature Switch: T_off (F) T_on (F)

Cycle Degradation Coefficients: Cd_c Cd_h

Design Heating Requirement: DHR Selection

Backup Heat-Fuel Combustion Data: Heat Value(MBtu/lb fuel) CO2 Emission(lbCO2/lb-fuel) Combustion Efficiency(%)

AHRI Std 210/240 Performance Data

Test Type	Capacity [Btu/hr]	Power [W]
Cooling, A Test, Indoor (80F/67F), Outdoor (95F/75F)	40704	3444
Cooling, A Test, Indoor (80F/67F), Outdoor (82F/65F)	45100	2931
Heating, H1 Test, Indoor (70F/-), Outdoor (47F/43F)	38600	3353
Heating, H2 Test, Indoor (70F/60F), Outdoor (35F/33F)	30912	3233
Heating, H3 Test, Indoor (70F/60F), Outdoor (17F/15F)	22199	3064

OK Cancel

ORNL LCCP Desktop App



Display cases using secondary refrigerants (ANSI/AHRI Standard 1320)

Input Values for Typical Secondary Coolant Display Case Parameters

Parameter	MT Multideck	MT Reach-in	LT Reach-in	LT Island
Secondary Coolant Flow Rate (GPM/ft)	0.50	0.40	0.65	0.35
Secondary Coolant Pressure Drop (psi/ft)	0.75	0.75	0.75	0.75
Fans (W/ft)	7.0	4.0	10	3.0
Lights (W/ft)	3.0	8.0	7.0	0.0
Anti-Sweat Heater (W/ft)	0.0	24	50	10
Defrost Heater (W/ft)	100	135	300	300
Refrigeration Load (BTUH/ft)	1400	800	550	510

OK

These values are given per foot of display case width

Display Case with Secondary Refrigerants Input

[Recommended Input Values](#)

Cycle Defrost Inputs			
Cut off temperature [K]	298.15	Condensate evaporator pan heaters time [h]	0.25
Secondary coolant pressure drop [psi]	7.5	Condensate evaporator pan heaters power [W]	0
Secondary coolant flow rate [gpm]	5.9	Anti-condensate heaters time [h]	0.25
Defrost heaters time [h]	0.25	Anti-condensate heaters power [W]	0
Defrost heaters power [W]	0	Average refrigerator load [Btu/hr]	16400
Fan motor efficiency [-]	1	Number of fan motors [-]	1
Lights time [h]	24	Defrost time [h]	2.4
Lights power [W]	294	Fan power [W]	60
Time fans [h]	24	Test unit time [h]	24
EER equation as function of ambient dbt	dbt**1/20	**The equation must be in terms of outdoor DBT "dbt"	

OK Cancel

ORNL LCCP Desktop App

Water chiller system (ANSI/AHRI Standard 550/590)

Water Chiller System Inputs ✖

Full Capacity [Btu/hr]

Ambient temperature [F]

EER Equation *

* The equation must be in terms of outdoor DBT "dbt", and part load factor "PLF"

Capacity and EER Values

Capacity [Btu/hr]	EER [-]
1320055.55	9.558
990041.66	12.074
660027.77	13.549
330013.89	13.009
0	0

ORNL LCCP Desktop App

System

- VapCyc based
 - Interchange component models
 - Refrigerant mixtures
 - User-defined components and fluids
- User-defined

Loads

- Text file
- EnergyPlus
- User defined

ORNL LCCP Desktop App

- 🌱 TMY3 weather data (predefined cities)
- 🌱 Multiple cycles system
- 🌱 Comparison of different systems
- 🌱 Multi-dimensional parametric analysis
- 🌱 Sensitivity analysis
- 🌱 Uncertainty analysis
- 🌱 Consider effect of charge degradation on system performance

LCCP Applications Comparison

Supermarket refrigeration system

LCCP Application	Web-based	Desktop
No. of cycles	Single	Multi
Cycles	LT, MT, MT-LT	Any
Simulation software	VapCyc	Any
No. of cities	47	47 + User defined
Load profile	Built-in	Built-in, file-based, EnergyPlus
Parametric Analysis	N/A	Multi parameters
GWP, CO ₂ Eq. values	Fixed	User modified

LCCP Applications Comparison

ASHP system

LCCP Application	AHRI	ORNL-LCCP	
	MS Excel based	Web	Desktop
Design Capability	No	Yes	Yes
System Type	3 + custom	3	3 + custom
Units	English/SI	English/SI/Modified	English/SI/Modified
No. of Cities	41 + User defined	41	41 + User defined
Refrigerants	13 + User defined	13	13 + User defined
Performance Calculation	AHRI std/Simple SEER	AHRI std/Simple SEER	AHRI std/Simple SEER
CO2 from Manufacturing/EOL	Simple/Detailed	Simple	Simple

AHRI tool: <http://www.ahrinet.org/technical+results.aspx>

LCCP Desktop Version Demo

ASHP System Information

System Type: Performance:

Calculation Type: Backup Heat:

Unit Temperature Switch: T_off (F) T_on (F)

Cycle Degradation Coefficients: Cd_c Cd_h

Design Heating Requirement: DHR Selection


Backup Heat-Fuel Combustion Data: Heat Value(MBtu/lb fuel) CO2 Emission(lbCO2/lb-fuel) Combustion Efficiency(%)

AHRI Std 210/240 Performance Data

Test Type	Capacity [Btu/hr]	Power [W]
Cooling(high), A2 Test, Indoor (80F/67F), Outdoor (95F/75F)	36526	2971
Cooling(high), B2 Test, Indoor (80F/67F), Outdoor (82F/65F)	39214	2656
Cooling(Low), B1 Test, Indoor (80F/67F), Outdoor (82F/65F)	28077	1572
Cooling(low), F1 Test, Indoor (80F/67F), Outdoor (67F/53.5F)	31000	1400
Heating(High), H12 Test, Indoor (70F/60F), Outdoor (47F/43F)	37585	2993
Heating(High), H22 Test, Indoor (70F/60F), Outdoor (35F/33F)	31105	2732
Heating(High), H32 Test, Indoor (70F/60F), Outdoor (17F/15F)	23968	2531
Heating(Low), H01 Test, Indoor (70F/60F), Outdoor (62F/56.5F)	32000	2232
Heating(Low), H11 Test, Indoor (70F/60F), Outdoor (47F/43F)	25255	2054
Heating(Low), H21 Test, Indoor (70F/60F), Outdoor (35F/33F)	21190	1959

OK Cancel

LCCP Desktop Version Demo




Results		
Result Type	Value	% Value
City Name	Chicago, Illi...	
Refrigerant	R410A	
Total Emissions[kgCO2-Eq]	109999.86	
Total Direct Emissions[kgCO2-Eq]	8523.90	
Emissions - Annual Leakage[kgCO2-Eq]	7103.25	6.46
Emissions - EOL[kgCO2-Eq]	1420.65	1.29
Emissions - Service[kgCO2-Eq]	0.00	0.00
Emissions - Accidents	0.00	0.00
Emissions - Ref. Production and Transportation	0.00	0.00
Total Indirect Emissions[kgCO2-Eq]	101475.96	
Emissions - Energy Consumption[kgCO2-Eq]	100986.02	91.81
Emissions - Materials[kgCO2-Eq]	421.39	0.38
Emissions - Recycling[kgCO2-Eq]	22.01	0.02
Emissions - Charge[kgCO2-Eq]	46.54	0.04
Emissions - Refrigerant Disposal	0.00	0.00
Emissions - System Transport	0.00	0.00
Annual Energy Consumption[kgCO2-Eq]	6732.40	

LCCP Desktop Version Demo

Parameters

Charge +/- 10 %

Power Plant Emission +/- 10 %



LCCP Desktop Version Demo

Inputs | Results | Sensitivity Analysis | Results -ALT | **Uncertainty Analysis**

Input Parameters	Current Value [SI Units]	Uncertainty(absolute)	Uncertainty(%)
Refrigerant EOL Disposal	0		1
Reused Refrigerant	0.8		1
Service Leakage Rate	0.05		1
Ref Production & Transportation	0		1
Refrigerant Loss EOL	0.1		1
Accidents Leakage Rate	0		1
Annual Leakage Rate	0.1		1
Charge	3299.9		1

Results

[Copy results data to clipboard](#)

Parameters	Current Value	Uncertainty Absolute	Uncertainty Percent
Total Emissions	48608192.62	48608192.62 +/- 566763.42	48608192.62 +/- 1.17 %
Total Direct Emission	33649693.45	33649693.45 +/- 545724.74	33649693.45 +/- 1.62 %
Annual Leakage Emission	25884379.58	25884379.58 +/- 448330.61	25884379.58 +/- 1.73 %
Refrigerant EOL Emission	1294218.98	1294218.98 +/- 22416.53	1294218.98 +/- 1.73 %
Production Emission	0	0 +/- 0	0 +/- 0 %
Accidents Emission	0	0 +/- 0	0 +/- 0 %
Servicing Emission	6471094.89	6471094.89 +/- 112082.65	6471094.89 +/- 1.73 %
Total Indirect Emission	14958499.17	14958499.17 +/- 148387.26	14958499.17 +/- 0.992 %
Energy Consumption Emission	14837261.01	14837261.01 +/- 148372.61	14837261.01 +/- 1 %
Materials Emission	0	0 +/- 0	0 +/- 0 %
Recycling Emission	0	0 +/- 0	0 +/- 0 %
Charge Emission	121238.16	121238.16 +/- 2085.39	121238.16 +/- 1.72 %
Refrigerant EOL Emission	0	0 +/- 0	0 +/- 0 %
Equipment Transport	0	0 +/- 0	0 +/- 0 %

Parameters	Current Value	Uncertainty Absolute	Uncertainty Percent	Partial Derivative
Refrigerant EOL Disposal	0	0 +/- 0	0 +/- 1%	0
Reused Refrigerant	0.8	0.8 +/- 0.008	0.8 +/- 1%	-55108.2566
Service Leakage Rate	0.05	0.05 +/- 0.0005	0.05 +/- 1%	129421897.83
Ref Production & Transportation	0	0 +/- 0	0 +/- 1%	0
Refrigerant Loss EOL	0.1	0.1 +/- 0.001	0.1 +/- 1%	12942189.8
Accidents Leakage Rate	0	0 +/- 0	0 +/- 1%	0

Project Team

- 🌱 Oak Ridge National Labs (ORNL)
 - Omar Abdelaziz (abdelazizoa@ornl.gov)
 - Ed Vineyard
 - Brian Fricke
- 🌱 University of Maryland (UMD)
 - Vikrant Aute (vikrant@umd.edu)
 - Reinhard Radermacher
 - Lopamudra Vemulapalli
 - Mohamed Beshr

Thank You

