



11<sup>th</sup> IIR Gustav Lorentzen Conference on Natural Refrigerants  
*Natural Refrigerants and Environmental Protection*

# **Low GWP R-410A Alternatives in Heat Pumps: “Drop-in” LCCP Evaluation**

**2014**

**Gang Li**

**Yunho Hwang**

**Center for Environmental Energy Engineering**

**Department of Mechanical Engineering**

**University of Maryland**

**College Park, MD 20742-3035**



# Outline

- **Introduction**
- **Experimental Apparatus**
- **Heat Pump Performance**
- **LCCP Assumptions**
- **LCCP Evaluation under Different US Cities**
- **LCCP Sensitivity Analysis**
- **Conclusions**



## Motivation

- Low GWP replacements needed in HVAC applications

**ODP=0**



**ODP=0 Low GWP**

R-410A GWP: 2,088

R-32

GWP: 675

L-41a

GWP: 494

D2Y60

GWP: 272

- AHRI supports AREP program
- LCCP analysis needed to evaluate the environmental impact (GHG emissions)
- Currently limited LCCP evaluation for low GWP refrigerants in HPs





# Refrigerant Properties

**Table 1: Comparison of Thermophysical Properties of Refrigerants**

Parameter	Unit	R-410A		R-32		L-41a		D2Y60	
Temperature	° C	44	10	44	10	44	10	44	10
Sat. Vapor Pressure	kPa	2,653	1,081	2,73	1,107	2,490	1,016	2,217	924.7
Temperature Glide	K	0.1	0.1	0	0	2.2	2.5	5	5.8
Sat. Liquid Density	kg/m <sup>3</sup>	953.2	1133	872	1,020	896.3	1,044	928.2	1,074.3
Sat. Vapor Density	kg/m <sup>3</sup>	115.6	41.9	82.4	30.2	81.17	29.68	81.9	30.3
Latent Heat	kJ/kg	151.7	209.9	226	298.9	197.4	258.0	158.6	204.6
Sat. Liq. Spec. Heat	kJ/(kg-K)	2.04	1.57	2.25	1.8	2.07	1.68	1.83	1.5
Sat. Vap. Spec. Heat	kJ/(kg-K)	2.02	1.227	2.06	1.344	1.83	1.23	1.5	1.1
Sat. Liq. Therm.	mW/(m-K)	75.1	98.1	105	136.4	95.29	117.5	74.2	91.5
Conductivity									
Sat. Vap. Therm.	mW/(m-K)	18.7	13.6	21.4	15.3	18.93	12.7	17.8	12.7
Conductivity									
Sat. Liquid Viscosity	μPa-s	92	147.3	92.6	139.5	92.3	138.7	96.6	145.4
Sat. Vapor Viscosity	μPa-s	15.7	12.7	14	12	14.4	12.3	14.4	12.3
Vol. Cooling Capacity	kJ/m <sup>3</sup>	-	8,804	-	9,039	-	7,656	-	6,202
GWP	-		<b>2,088</b>		<b>675</b>		<b>494</b>		<b>272</b>



# Experimental Apparatus



*Figure 1: Schematic of Test Facility setup.*



# Test Matrix

Table 2: ASHRAE Standard 116 (2010) Test Matrix

Test	Indoor		Outdoor		Operation
	Db (°C)	Wb (°C)	Db (°C)	Wb (°C)	
Extended Conditions			46.1		Steady State Cooling
A		19.4	35		Steady State Cooling
B	26.7			NA	Steady State Cooling
C		≤13.9	27.8		Steady State Cooling, Dry Coil
D					Cyclic Cooling, Dry Coil
High Temp. 2			8.3	6.1	Steady State Heating
High Temp. 1			16.7	14.7	Steady State Heating
Low Temp.			-8.3	-9.4	Steady State Heating
Extended Conditions	21.1	≤15.6	17.8	NA	Steady State Heating
High Temp. Cyclic			8.3	6.1	Cyclic Heating
Frost Acc.			1.7	0.6	Steady State Defrost

Cooling

Heating



# LCCP Assumptions

System Lifetime [yr]

Number of Cycles

System Property	Cycle 1
System Type [-]	ASHP
Refrigerant [-]	R410A
System Charge [lb]	11.7
Nominal Load [Btu/hr]	36000
Annual Leakage Rate [%]	5
Ref Loss EOL [%]	15
Service Interval [yr]	5
Service Leakage Rate [%]	5
Ref Disposal Energy [lbCO <sub>2</sub> -Eq]	0
Reused Refrigerant [%]	85
Accident Leakage [%]	0.3
Ref Production & Transportation[%]	0
Equipment Transport [lbCO <sub>2</sub> -Eq]	0
Aluminum Castings [lb]	15
Aluminum Forgings [lb]	10
Steel Forgings [lb]	10
Wrought Aluminum [lb]	25
Rubber [lb]	5
Copper [lb]	30
Plastics [lb]	5
Brass [lb]	0


Refrigerant

Charge amount

- **Unit temp. switch:**
  - T<sub>off</sub>: 0 F
  - T<sub>on</sub>: 10 F
- **Back up heat combustion data:**  
**Combustion efficiency 80%**



# Heat Pump Performance









# Heat Pump Performance- Charge Effects

## Cooling A



**R-410A**




**R-32**

- As the refrigerant charge amount is increased, the cooling capacity is increased and COP is increased first and then decreased




## Heat Pump Performance- Charge Effects

### Cooling A



### L-41a




### D2Y60

- As the refrigerant charge amount is increased, the cooling capacity is increased and COP is increased first and then decreased




# LCCP Evaluation under Different US Cities









# LCCP Evaluation under Different US Cities







# LCCP Evaluation under Different US Cities





# LCCP Sensitivity Analysis

## Effect of COP Improvements




- It has high influence on CO<sub>2</sub> emissions
- Direct emissions remain constant



# LCCP Sensitivity Analysis

## Effect of Annual Leakage Rates





- It has high influence on CO<sub>2</sub> emissions
- Indirect emissions remain constant
- Direct emissions varied (due to annual leakage)



# LCCP Sensitivity Analysis

## Effect of Refrigerant EOLs



Refrigerant EOL

Refrigerant EOL



- It has small influence on CO<sub>2</sub> emissions
- Indirect emissions remain constant
- (All these conclusions can be analyzed with emission distributions in slide page 11)





# LCCP Sensitivity Analysis

## Effect of Service Leakage Rates




- It has small influence on CO<sub>2</sub> emissions
- Indirect emissions remain constant




# LCCP Sensitivity Analysis

## Effect of Accident Leakage Rates



Accident Leakage Rate




Accident Leakage Rate

- It has high influence on CO<sub>2</sub> emissions
- Indirect emissions remain constant
- (All these conclusions can be analyzed with emission distributions in slide page 11 )



# LCCP Sensitivity Analysis

## Effect of Refrigerant Charge



- COP and capacity results with different refrigerant charge amount were used for LCCP evaluation
- Both direct and indirect emissions are increased



## Conclusions

- In general, R-32 has about 4% CO<sub>2</sub> emission reduction as compared with R-410A.
- Lower capacity refrigerants (L-41a and D2Y60) have the reduction of around 17% and 27%, respectively.
- But their proper evaluation should be made after capacity matching.
- Mild area has lower CO<sub>2</sub> emissions than that of cold and hot areas.
- R-410A has a high direct emission contribution (14.2%) while its alternatives have lower within 4%.
- COP improvement has a highest impact on CO<sub>2</sub> emission reduction.



# Thank You!

# Any Questions?

